

Received:04/30/2008 Completed:05/06/2008 Letter: F3 rb P.O.#: Test Report #: 2-73356-3-

Client's Identification Style: Remix by Kvadrat.

Tested For: **Anna DeMatteo** Key Test: NFPA 260 Cover Fabric (BLDG) 105
Maharam
45 Rasons Court Tel: 1-(631)-851-3342 Ext:
Hauppauge, NY 11788 Fax: 1-(631)-342-0264

PC: 4H /jd

TEST PERFORMED: NFPA 260 Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture; Cover Fabric Test

RESULTS:	TEST		RETEST (If Required)	
	Ignition (yes/no/SE)	Char Length On Vertical Panel (mm)	Ignition (yes/no/SE)	Char Length On Vertical Panel (mm)
Specimen #				
1	SE	10	SE	10
2	SE	10	SE	10
3	SE	10	SE	10

ABBREVIATION WHICH MAY BE USED:

SE: Indicates that the cigarette self extinguished prior to burning its entire length. When this occurs, a "retest" of that specimen is performed.

REMARKS: None.

CLASSIFICATION SYSTEM:

Class I - For each specimen: No obvious ignition; maximum char length 45 mm (1.75").
(Indicates propensity to resist cigarette ignition in conjunction with standard foam filling material.)

Class II - For any specimen: Obvious ignition; or char length exceeding 45 mm (1.75").
(Indicates inability to resist cigarette ignition in conjunction with standard foam filling material.)

CONCLUSION: Based on the above Results and Classification System, the item tested is assigned a:

Class I rating; Class II rating



Received:04/30/2008	Completed:05/06/2008	Letter: F3	rb	P.O.#:	Test Report #:	2-73356-3-
---------------------	----------------------	------------	----	--------	----------------	------------

Client's Identification	Style: Remix by Kvadrat.
-------------------------	--------------------------

Tested For: Anna DeMatteo Maharam 45 Rasons Court Hauppauge, NY 11788	Key Test: NFPA 260 Cover Fabric (BLDG) 105 Tel: 1-(631)-851-3342 Fax: 1-(631)-342-0264	Ext:
---	--	------

CODE INFORMATION: In accordance with --

- (1) The 2006 Edition of the NFPA Life Safety Code 101 paragraph 10.3.2.1(1);
- (2) The 2006 Edition of the International Fire Code, paragraph 805.1.1.1, 805.2.1.1 and 805.3.1.1

Upholstered furniture components shall be Class I when tested in accordance with NFPA 260, when used in:

- Detention or correctional occupancy
- Health care occupancy
- Residential board & care occupancy

In certain situations an exception is made if the rooms or areas are sprinklered.

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by NFPA 260.

Heather S. Robertson

AUTHORIZED SIGNATURE
THE GOVMARK ORGANIZATION, INC. /jb
MS. HEATHER ROBERTSON

(Page 2 of 2)